

WWW.CLARKNEXSEN.COM

4

NEW WORK KEYED NOTES:

(1) PROVIDE NEW DUKANE PA SPEAKER TO MATCH EXISTING PA SYSTEM AT HOSPITAL. MAKE ALL CONNECTIONS TO EXISTING PA SYSTEM AS

(2) NEW FIRE ALARM DEVICE. MAKE ALL CONNECTIONS TO EXISTING

(3) PROVIDE NEW DATA OUTLET IN THIS APPROXIMATE LOCATION. DATA DROPS SHALL BE REROUTED/CONFIGURED FROM EXISTING DATA OUTLETS BEING REMOVED IN RENOVATED SPACES.

(4) FLOW AND TAMPER SWITCHES IN STAIRWELLS OF ALL FLOORS.

(5) FLOW AND TAMPER SWITCHES IN STAIRWELL OF NINTH FLOOR FOR SHAFT SPRINKLERS.

(6) DEDICATED FIREFIGHTER TWO WAY COMMUNICATIONS PHONE OUTLET. CONTRACTOR SHALL COORDINATE EXACT LOCATION PRIOR TO INSTALLATION AND ROUTE NECESSARY CABLING BACK TO FACP AS REQUIRED FOR A COMPLETE SYSTEM.

(7) CEILING MOUNTED SMOKE DETECTOR FOR DOOR HOLD OPEN HARDWARE. COMBINATION HOLD OPEN/CLOSER PROVIDED WITH DOOR

(8) CABLE RUNWAY, 24" WIDE.

- (9) PROVIDE DATA OUTLET AND VIDEO OUTLET ABOVE CEILING FOR OVERHEAD PROJECTOR. COORDINATE EXACT LOCATION PRIOR TO ROUGH-IN. CONTRACTOR SHALL COORDINATE EXACT CABLE/VIDEO REQUIREMENTS WITH VA PRIOR TO INSTALLATION.
- (10) APPROXIMATE LOCATION OF INTERCOM. PROVIDE EMPTY JUNCTION BOX WITH 3/4" CONDUIT ROUTED TO ABOVE ACCESSIBLE CEILING. COORDINATE EXACT LOCATION PRIOR TO INSTALLATION.
- (11) PROVIDE 2 DATA/1 VOICE DATA LOCATION AT FLOOR BOX.
- (12) PROVIDE FLUSH MOUNTED MATV/CATV OUTLET AT 72" ABOVE FINISHED FLOOR. COORDINATE EXACT MOUNTING LOCATION PRIOR TO ROUGH-IN.
- (13) ACCESS CONTROL LOCATIONS. PROVIDE PROXIMITY SENSOR WITH DOOR STATUS MONITOR AND PROXIMITY/INFRARED SENSOR. PROVIDE JUNCTION BOX WITH 3/4" CONDUIT TO HIRSCH PANEL IN IT CLOSET 403. COORDINATE EXACT LOCATION.
- (14) 12" LADDER TYPE ALUMINUM CABLE TRAY. SEE DETAIL, SHEET E501.
- (15) PROVIDE (3) 4" CONDUIT SLEEVES THROUGH FLOOR AND INTO CEILING OF IT 310 ON 3RD FLOOR. PROVIDE WITH NYLON PULLSTRING.
- (16) SEE LARGE SCALE PLAN, SHEET EP401.
- (17) WOOD BACKBOARD ON ALL WALL SURFACES INSIDE IT CLOSET. PROVIDE ANGLE SUPPORT FRAME FOR RIGID SUPPORT AND CLEAN INSTALLATION. PAINT ALL BACKBOARDS GRAY. PROVIDE 110 BLOCKS AS REQUIRED FOR TERMINATIONS OF NEW VOICE DROPS THROUGHOUT FOURTH FLOOR.
- (18) 18" LADDER TYPE, ALUMINUM CABLE TRAY WITH RUNG SPACING EVERY 12" MINIMUM.
- (19) STANDARD TELECOMMUNICATIONS FLOOR RACK. PROVIDE PATCH PANELS AS REQUIRED FOR TERMINATION OF NEW DATA DROPS THROUGHOUT FOURTH FLOOR AND FIBER CONNECTIONS.
- (20) SEE NEW WORK SPECIAL SYSTEMS PLAN ROOM 403, THIS SHEET.
- (21) 110 PUNCHDOWN BLOCKS.
- (23) FIRE ALARM, CATV, NURSE CALL, PA, CCTV, ACCESS CONTROL MOUNTING LOCATIONS.

FINAL SUBMITTAL

MOLNAR 404.214.9774

667-083 OVERTON BROOKS VAMC uilding Number: rawing Number: SHREVEPORT, LA

hecked:

CBC

SJB

Dwg.

07-20-2015

OFFICE OF CONSTRUCTION AND FACILITIES **MANAGEMENT**

VA U.S. Department of Veterans Affairs

ET102 156 of 16